

WILLIAM L. KORBEB, L.S.
JOHN E. LUNDBLADE, L.S.
N. BRENT WOOTEN, P.E.



BAUGHMAN COMPANY, P.A.

SURVEYING & ENGINEERING


316/262-7271 • 330 LAURA • WICHITA, KANSAS 67211

State of Kansas)
) SS January 21, 1983
County of Sedgwick)

We, Baughman Company, P.A., Surveyors in aforesaid county and state do hereby certify that we did on this 21st day of January, 1983, find the existing first floor elevation of the structure at 928 Sumney (Lot 22, Block 3, Replat of Sunset Fields) to be 1266.52 mean sea level.

William L. Korber

Surveyor



HAYSVILLE, KS.
Building Insp.
200 W. Grand
524-3243

Be
5-30-3

CITY OF HAYSVILLE

CERTIFICATION OF ELEVATION

BUILDING PERMIT NO. 2094
 ADDRESS 928 Summey
 LEGAL DESCRIPTION LOT 22, BLD 3 Replat of
Sunset Fields, Haysville, KS
 CONTRACTOR SELF

"This location is within the Special Flood Hazard Area as identified by the Department of Housing and Urban Development on the Flood Insurance Rate Map."

The Main Floor shall be elevated to/or above elevation 1266 feet MSL.

Basements to be constructed in accordance with "Manual for the Construction of Residential Basements in Non-Coastal Flood Environs".

This is to certify that the structure listed in Building Permit No. 2094 does meet the requirements of the City of Haysville, Kansas.

Main Floor Elevation 1266.52 MSL.

basement constructed in accordance with, "Manual for the Construction of Residential Basements in Non-Coastal Flood Environs".

YES NO **BASEMENT ALLOWED**

Signed William Kauls **Brighman Co.**
 R.L.S. / Engineer / Architect Supervisor

Date JAN 21, 1983

HAYSVILLE, KS.
Building Inspr.
200 W. Grand
524-3243

Note: This Document shall be kept on file in the official community file of records for buildings constructed in the special flood hazard Area.