

CITY OF HAYSVILLE

CERTIFICATION OF ELEVATION.

BUILDING PERMIT NO. 2066  
 ADDRESS 6400 S Osage  
 LEGAL DESCRIPTION LOT 1 Block 5 Sunset Fields Osage  
 CONTRACTOR Higgins Const.

2:00 PM 7 Oct 1982  
 Transfer elevation  
 from Campbell & Castle

"This location is within the Special Flood Hazard area as identified by the Department of Housing and Urban Development on the flood insurance rate map."

BM # 77 to  
 Hub @ Fc. Cor.  
 6400 S. Osage.  
 Elev. @ Hub  
 1262.78

The Main Floor shall be elevated to/or above elevation 1266 feet MSL.

1262.7  
 3.3  
 1266.0

Basements to be constructed in accordance with "Manual for the Construction of Residential Basements in Non-Coastal Flood Environs".

Fill 3'-3" to  
 top Fdn Wall

This is to certify that the structure listed in building Permit No. 2066 does meet the requirements of the City of Haysville, Kansas.

J. Daniel  
 T.L. Daniel  
 LS # 489

Main Floor Elevation \_\_\_\_\_ MSL.

Basement constructed in accordance with, "Manual for the Construction of Residential Basements in Non-Coastal Flood Environs".

Yes / No \_\_\_\_\_

(X)

Signed \_\_\_\_\_  
 P.E. / Engineer / Architect

(X)

Date \_\_\_\_\_

Note: This Document shall be kept on file in the official community file of records for buildings constructed in the Special Flood Hazard Area.